



NOTES:

1. REMOVE ALL LEAD AND OTHER FLASHING BEFORE INSTALLING FIELD-FABRICATED PIPE SEAL.
2. SECUREMENT REQUIRED AROUND ALL PIPES GREATER THAN 18" (500 mm) IN DIAMETER.
3. QUICK APPLIED UNCURED EPDM FLASHING WRAPPED AROUND THE PIPE SHALL HAVE 3" (75 mm) MINIMUM SPLICE.
4. IN COLDER TEMPERATURES, A HEAT GUN MUST BE USED WHEN FORMING QUICK APPLIED UNCURED EPDM FLASHING.
5. ON MECHANICALLY ATTACHED ROOFING SYSTEMS, ADDITIONAL MEMBRANE SECUREMENT IS REQUIRED. REFER TO DETAIL MA-14.

C-14.1

FIELD FABRICATED PIPE SEAL