



## VERSIFLEX™ PIPE SEALS



### Overview

Versico's VersiFlex PVC Pipe Seals are injection-molded, pre-formed flashings for pipes .75" (19 mm) to 8" (203 mm) in diameter. This labor saving accessory provides a quick and reliable way to waterproof round pipe penetrations.

VersiFlex PVC Pipe Seals are part of Versico's Certified Fabricated Accessory (CFA) program. Certified Fabricated Accessories are the only factory-fabricated PVC accessories that meet the stringent quality tolerances required to be included in a Versico warranted roofing system.

### Features and Benefits

- Provides a reliable method of waterproofing round pipe penetrations
- Provides a substantial labor savings compared to field-fabricating from non-reinforced flashing
- Provides a more consistent appearance than field-fabricated pipe flashings
- Double-ribbed cutting guide facilitates easier, smoother, and straighter cuts
- Rib design holds the clamp in the proper position

### Installation

1. Cut Pipe Seal between double-ribbed cutting guide, one size smaller than pipe diameter. Do not cut off raised ring.
2. Pull Pipe Seal over pipe until base flange is in contact with the membrane. It may be necessary to apply heat to the top portion of the Pipe Seal to allow installation over the pipe.
3. Mark pipe around the top of the Pipe Seal.
4. Pull Pipe Seal upwards on pipe until mark on the pipe is visible.
5. Apply Universal Single-Ply Sealant below the mark that indicates the top of the installed Pipe Seal.
6. Pull Pipe Seal back down over pipe and into position.
7. Heat-weld the Pipe Seal base flange to deck membrane.
8. Install a stainless steel universal clamping ring to provide constant compression of the sealant.

REVIEW CURRENT VERSICO SPECIFICATIONS AND DETAILS FOR SPECIFIC INSTALLATION REQUIREMENTS.

### Precautions

1. Remove all lead and other flashing.
2. Temperature of pipe must not exceed 140°F (60°C).
3. Install a minimum of four fastening plates around pipe penetrations. Position fastening plates around the penetration so they are covered by the Pipe Seal flange. A minimum 1½"-wide weld must be maintained around the outer edge of the flange beyond the plates. If fastening plates cannot be installed in a manner to allow a minimum 1½" weld, the plates must be placed outside the Pipe Seal flange and covered with a reinforced VersiFlex membrane overlay.
4. Store Pipe Seals in a cool, shaded area and cover with light-colored, breathable, waterproof tarpaulins. VersiFlex Pipe Seals or membrane that have been exposed to the weather must be prepared with PVC Membrane Cleaner prior to hot-air welding.

## TYPICAL PROPERTIES AND CHARACTERISTICS

Property	Value
Sizes	¾" to 8" O.D. Pipe (19 to 203 mm)
Packaging	8/Box
Weight (each)	0.55 lbs (0.25 kg)
Material	PVC compound
Color	White, Tan, and Gray

Typical properties and characteristics are based on samples tested and are not guaranteed for all samples of this product. This data and information is intended as a guide and does not reflect the specification range for any particular property of this product.

Please use the chart below to cross-reference your pipe size with the proper step to cut as shown.

COPPER TUBING (C.T.S.)												
Nominal Tube Size	¾"	1"	1 ¼"	1 ½"	2"	2 ½"	3"	4"	5"	6"	8"	
Pipe O.D.	.88	1.13	1.38	1.63	2.13	2.63	3.13	4.13	5.13	6.13	N/A	
Step of Boot Used	1	1	1	1 ½	2	2	3	4	5	6	N/A	
SCHEDULE 40/80 STEEL PIPE - PVC STANDARD - POLYETHYLENE PIPE IPS												
Nominal Pipe Size	¾"	1"	1 ¼"	1 ½"	2"	2 ½"	3"	4"	5"	6"	8"	
Pipe O.D.	1.05	1.32	1.66	1.90	2.38	2.88	3.50	4.50	5.56	6.63	8.63	
Step of Boot Used	1	1	1 ½	1 ½	2	3	3	4	5	6	8	
CAST-IRON PIPE												
	Pit Class A & Spun 100-250					Pit Class B, C & D						
Nominal Pipe Size	2"	3"	4"	6"	8"	2"	3"	4"	6"	8"		
Pipe O.D.	2.50	3.96	4.80	6.90	9.50	N/A	3.96	5.00	7.10	9.30		
Step of Boot Used	2	4	5	6	N/A	N/A	4	5	6	N/A		
SEWER - SOIL PIPE												
	PVC Plastic SDR 35 & 41...Cast Iron Soil Pipe no hub...service weight & extra heavy											
Nominal Pipe Size	4"	4"	4"	4"	6"	6"	6"	6"	8"	8"	8"	8"
Pipe O.D.	4.22	4.38	4.30	4.62	6.28	6.30	6.30	6.62	8.40	8.38	8.38	8.75
Step of Boot Used	4	4	4	4	6	6	6	6	8	8	8	8
CONDUIT EMT												
Nominal Pipe Size	¾"	1"	1 ¼"	1 ½"	2"	2 ½"	3"	3 ½"	4"			
Pipe O.D.	.922	1.16	1.51	1.74	2.19	2.88	3.50	4.00	4.50			
Step of Boot Used	1	1	1	1 ½	2	3	3	4	4			
CONDUIT IMC												
Nominal Pipe Size	¾"	1"	1 ¼"	1 ½"	2"	2 ½"	3"	3 ½"	4"			
Pipe O.D.	1.02	1.29	1.63	1.88	2.36	2.85	3.47	3.97	4.46			
Step of Boot Used	1	1	1 ½	1 ½	2	3	3	4	4			
CONDUIT RIGID												
Nominal Pipe Size	¾"	1"	1 ¼"	1 ½"	2"	2 ½"	3"	3 ½"	4"	5"		
Pipe O.D.	1.05	1.32	1.66	1.90	2.37	2.87	3.5	4	4.5	5.56		
Step of Boot Used	1	1	1 ½	1 ½	2	3	3	4	4	5		